



ADDENDUM
RFQ REC-2026-03
Issued: August 28, 2026

SCOPE

The purpose of the addendum is to clarify the required specifications as follows and to share information about bottom layers of current roof system:

The required roofing system shall consist of:

1. Self-adhered vapour barrier
2. Adhered roofing system (no mechanical fastening or puncturing of the existing roof assembly)
3. Adhered insulation
4. Adhered 2 in 1 Smart Board
5. Torch applied 250 cap sheet membrane

The existing roof assembly was determined to consist of 1½" SM Board insulation installed over a kraft-faced vapour barrier.

ACKNOWLEDGEMENT

Please include this signed Acknowledgement of Addendum in the submitted proposal package.

--	--	--

Name

Signature

Date