

**RFP 2026-13 PJYCC Sound System Upstairs Lounge
INQUIRIES to August 24 2026**

Do you want speakers replaced?

Yes.

Are both sets of speakers in use? Can ceiling tiles be replaced?

We are not aware of which speakers are currently functional. Ceiling tiles can be replaced if new speakers do not work in existing holes.

Are there corded mics?

No – just wireless mics.

Do you want control away from the equipment, on an iPad for example, or at the equipment itself?

At the equipment itself.

Number of rooms with sound

One.

Room location of round speakers vs. square speakers.

See attachment on Township website, Bids & Tenders page.

Current status of square speakers (active/in use).

We are not aware of which speakers are currently functional. When radio is being played, only the circle type speakers are playing radio. Should circle speakers be the ones that serve the current sound system, the circle ones are the ones that can be removed and replaced and the square can stay. If the square ones are found to have no use, they can be removed.

Is there any Paging if so ,can you provide system routing detail.

No paging program is currently used or required now.

Intended usage for the Main Hall (background vs. loud musical functions)

Generally used for playing background music, speeches at events, as a microphone for an emcee at community events such as trivia nights. Not intended to replace the sound requirements for a live band playing on the stage.

Is there any existing wall volume controls for the rooms?

No.

Audio quality requirements (Contractor level vs. Pro Commercial Audio).

We are seeking standard commercial-quality equipment suitable for community hall use. High-end, professional audio quality is not required.

Is it possible to get a picture of the main hall.

See attachment on Township website, Bids & Tenders page.