



August 27, 2026

**Addendum #4
for RFP No. RDS 26-04
Minden Library Retaining Wall**

This addendum shall be incorporated into and form part of RFP No. RDS 26-04 for RFP Minden Library Retaining wall

Receipt of the Addendum shall be acknowledged as part of your submission as per Section 2.14 – Addenda of the RFP document and **must be included** in the submission package before the closing date of **September 2, 2026 at 12:00 noon**.

The Township of Minden Hills reserves the right to reject any or all tenders or accept any proposal, should it deem such actions to be in the best interest of the Township.

Question 1: The retaining wall material supplier and their Engineers are indicating that the concrete grade beam specified is not sufficient for the application and must be wider to support the entire reinforced zone. Please advise if we are to continue pricing this job as originally designed, or if a wider grade beam will be used.

Answer 1: Please see below two alternatives that have been approved by the design engineer as well as product links.

1. Permacon Grande Wall [Permacon Grande Wall](#)
2. Allan Block AB Collection [Allan Block Retaining Walls](#)

This addendum consists of 2 pages.

If you have questions regarding this matter, please contact the Township directly as outlined in Section 2.13 – Inquiries of the RFP document.

Sincerely,

Mike Timmins
Director of Public Works

Acknowledgement of Receipt

Bidders are required to acknowledge receipt of all addenda by signing the Acknowledgement of Receipt below. Failure to submit all addenda will constitute an automatic rejection.

I/we hereby acknowledge receipt of this addendum and make allowances in my bid.

Signature of Bidder

Date

Name of Company